



CSA INTERNATIONAL

# Certificate of Compliance

**Certificate:** 1956330

**Master Contract:** 237337

**Project:** 1956330

**Date Issued:** 2008/03/28

**Issued to:** Specific Systems, Ltd

7655 E 41st St  
Tulsa, OK 74145  
USA  
Attention: Bob Bates

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



**Issued by:** Dennis Smith

**Authorized by:** Patricia Pasemko, Operations Manager

## PRODUCTS

**CLASS 1212 81** - COMFORT CONDITIONING EQUIPMENT (ELECTRICAL) - Central Type, Combination Cooling/Heating - Certified to U.S.

**CLASS 1212 01** - COMFORT CONDITIONING EQUIPMENT (ELECTRICAL) - Central Type, Combination Cooling/Heating

Permanently connected HVAC units with optional electric heat, INPAC series. Optional backup blower, and electric heat.

### Electrical Rating

### Alternate Rating

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



CSA INTERNATIONAL

Certificate: 1956330

Master Contract: 237337

Project: 1956330

Date Issued: 2008/03/28

Model	Vac	#Phases	Hz	A	Vac	# Phases	Hz	A	Capacity
<b>60 Series</b>									
61	208/230	3	60	20	115	1	60	35	1
62	208/230	3	60	30	208/230	1	60	40	2
63	230/480	3	60	20-40	208/230	1	60	50	3
<b>600 Series</b>									
624	240/480	3	60	25 to 65	240	1	60	50	2
636	240/480	3	60	30 to 75	240	1	60	69	3
648	240/480	3	60	40 to 85	240	1	60	124	4
660	240/480	3	60	40 to 95	240	1	60	142	5
<b>6000 Series</b>									
6090	240/480	3	60	50/150	240	1	60	125	7.5
6120	240/480	3	60	60/150	240/480	3	60	60/150	10
<b>8000 Series</b>									
8180	240/480	3	60	175/90	240/480	3	60	175/90	7.5
8240	240/480	3	60	200/100	240/480	3	60	200/100	10
<b>12000 Series</b>									
12180	240/480	3	60	137/71	575	3	60	60	15
12240	480	3	60	80	575	3	60	67	20
12300	480	3	60	110	575	3	60	92	25
12360	480	3	60	115	575	3	60	97	30



**Certificate:** 1956330

**Master Contract:** 237337

**Project:** 1956330

**Date Issued:** 2008/03/28

---

**APPLICABLE REQUIREMENTS**

- C22.2 No. 0-M91 - General Requirements – Canadian Electrical Code, Part II
- C22.2 No. 0.4-M2004 - Bonding and grounding of Electrical Equipment
- C22.2 No. 236-05 - Heating and Cooling Equipment
- UL 1995, 3rd Ed - Heating and Cooling Equipment

**MARKINGS**



## *Supplement to Certificate of Compliance*

**Certificate:** 1956330

**Master Contract:** 237337

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1956330	2008/03/28	Original Certification of INPAC Series

### **History**

### **Supplement Notes**