



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1956330

Master Contract: 237337

Project: 1956330

Date Issued: 2008/03/28

Issued to: Specific Systems, Ltd

7655 E 41st St
Tulsa, OK 74145
USA

Attention: Bob Bates

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Dennis Smith

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 1212 81 - COMFORT CONDITIONING EQUIPMENT (ELECTRICAL) - Central Type, Combination Cooling/Heating - Certified to U.S.

CLASS 1212 01 - COMFORT CONDITIONING EQUIPMENT (ELECTRICAL) - Central Type, Combination Cooling/Heating

Permanently connected HVAC units with optional electric heat, INPAC series. Optional backup blower, and electric heat.

Electrical Rating

Alternate Rating

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1956330

Master Contract: 237337

Project: 1956330

Date Issued: 2008/03/28

Model	Vac	#Phases	Hz	A	Vac	# Phases	Hz	A	Capacity
60 Series									
61	208/230	3	60	20	115	1	60	35	1
62	208/230	3	60	30	208/230	1	60	40	2
63	230/480	3	60	20-40	208/230	1	60	50	3
600 Series									
624	240/480	3	60	25 to 65	240	1	60	50	2
636	240/480	3	60	30 to 75	240	1	60	69	3
648	240/480	3	60	40 to 85	240	1	60	124	4
660	240/480	3	60	40 to 95	240	1	60	142	5
6000 Series									
6090	240/480	3	60	50/150	240	1	60	125	7.5
6120	240/480	3	60	60/150	240/480	3	60	60/150	10
8000 Series									
8180	240/480	3	60	175/90	240/480	3	60	175/90	7.5
8240	240/480	3	60	200/100	240/480	3	60	200/100	10
12000 Series									
12180	240/480	3	60	137/71	575	3	60	60	15
12240	480	3	60	80	575	3	60	67	20
12300	480	3	60	110	575	3	60	92	25
12360	480	3	60	115	575	3	60	97	30



Certificate: 1956330

Master Contract: 237337

Project: 1956330

Date Issued: 2008/03/28

APPLICABLE REQUIREMENTS

- C22.2 No. 0-M91 - General Requirements – Canadian Electrical Code, Part II
- C22.2 No. 0.4-M2004 - Bonding and grounding of Electrical Equipment
- C22.2 No. 236-05 - Heating and Cooling Equipment
- UL 1995, 3rd Ed - Heating and Cooling Equipment

MARKINGS



Supplement to Certificate of Compliance

Certificate: 1956330

Master Contract: 237337

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1956330	2008/03/28	Original Certification of INPAC Series

History

Supplement Notes